

V_Net Zero Crossing Module

Part Number: 220-VP-FWZX

Module Configuration Setup:

Module Type: SC_RPM

Channel Name: RF RPM

V_Net ID: Wheel Speed RF RPM x3B5

Sensor Type: Zero Crossing

Serial Number:

Channel Options:

Pulses per Revolution 5


V_Net Update Rate: 50 /second

Logger Sample Rate: 50 /second

Module Record Rate: 25 /second

Sensor Installation:

This module has been designed to interface a zero crossing (ac output) rpm sensor to the RacePak V_Net system. The module connector pin assignment is shown below.



We recommend using 5 magnets. If you decide to use a different number of magnets you will need to reprogram the pulses per revolution software setting in the V_Net module. **It is critical that the magnets are installed with equal distance between each of the 5 magnets. Also, the magnets supplied with the sensor are marked on one end with yellow ink. The magnets must be mounted with the yellow end face toward the sensor. The sensor will not work properly if the polarity of the magnet is not correct.**

Module Installation:

The V_Net connector module can be inserted at any location in the V_Net cable in your vehicle. Select locations where the connector module can be mounted safely. Avoid mounting near heat sources and high voltage ignition wires. The connector module must be mounted in a location the temperature does not exceed 185 degrees or the module will be damaged.



Module Setup:

The module has been factory configured as described in the setup box located at the top of this page. No further setup is required to begin using the module. In stand-alone V_Net system you must insure, however, that no other modules in your system have been assigned to the same V_Net ID as this module. If you already have a module in your system assigned to this ID you will either need to change the ID as described on the back of this setup sheet or exchange this module for one programmed with an appropriate ID.

If you are using the RacePak DataLink program to configure your V_Net system or to upload data from the system using a V50 Record/Playback module or a V300 or V500 data logger you will need to update your car configuration file before you will be able to access the information from this module. Please refer to the setup instructions on the back of this installation sheet.

Software Setup and Module Configuration

Before you can use this module as an upgrade to an existing V50 Module, V300 or V500 Data Logger you will need to update the Car Configuration File in your PC. To perform this step you will need to connect the V50 module or data logger to your PC using the units serial interface cable (See your units instruction manual for details). Next start the RacePak DataLink program. If you selected the your car configuration file as the default configuration file, the file will be opened and the file tab for the car configuration file will be selected. If it is not, open your car configuration file by selecting the **Open Car Configuration** menu item located in the **Files** main menu selection. Next apply power to your the board system, wait 10 seconds and select the **Read VNET Config** menu item located in the **Edit** main menu selection. The DataLink program will read in the configuration of your system. If everything works properly a new channel button, “Wheel RPM”, will be added to the configuration file.

However, if the new button is captioned as the module serial number (example: SN_12000), you have two modules in your system programmed using the same V_Net ID “Wheel RPM”. You must change the V_Net ID on one of the modules to something else like “Clutch RPM”. If you cannot find an appropriate V_Net ID in the list to match what the module is measuring you can use one of the User Custom ID’s found under the V_Net ID list.

To edit the setup parameters on this sensor module, position the mouse cursor over the channel button and click the right mouse button. The VNET Input Channel Parameters dialog box will be displayed. A Portion of this dialog box is show below.

Locate the box labeled **Unit Serial #**. Make sure the serial number is the same as the serial number of the module as shown in the module configuration box on the opposite side of this installation work sheet. If it is not, you are not editing the correct channel/sensor module. Check the other channel buttons to locate the correct sensor module.

CAN Input Channel Parameters

Name: Type:

Unit Serial #: Vnet ID:

Input Number: Sensor:


SINGLE CHANNEL RPM MODULE SETUP INSTRUCTIONS:

This channel represents a single channel RPM module connected to your V_Net System. Single channel RPM modules allow you to connect a single sensor such as an engine rpm, drive shaft rpm and/or a flowmeter type sensors to your system. Once connected the information from the sensor is available for use by the remainder of the V_Net System for display, recording, or control.

These modules are also capable of recording the data measured by the

Locate the text box labeled **Single Channel RPM Module Setup Instructions**. This text box provides online instructions for modifying the setup of this module. Read the instructions and modify the setup as desired. (Please note the scroll bars located on the left- hand portion of the text box are used to scroll through the instructions.

When you have finished editing the configuration on your PC, you will need to send the information to the sensor module. Be sure the serial interface cable is connected to your V50 unit or data logger and power is applied to the system. To send the information position the mouse cursor over the **Send Configuration** button and click the left mouse button. The progress box as shown to the left will be displayed.



When finished sending the message “**Device Programmed Successfully**” should be displayed at the bottom of the progress box. If you receive an error message, turn power to the system off and then back on and repeat the send configuration process. If problems persist, check the troubleshooting section in your manual and then contact RacePak.

Message Log

_CHART_MIN:
00052: 0034 00 00 81 00

_CHART_MAX:
00053: 0035 30 75 fe 00

COPY_TUT_COMMAND:
16386: 4002 00 00 00 00

REBOOT_COMMAND:
16450: 4042 00 00 00 00

==== DEVICES PROGRAMMED SUCCESSFULLY ====

Update the Module Configuration Setup Box on the front of this worksheet with the new setup configuration.

IMPORTANT:

Save this Installation Worksheet in your System Manual in Appendix V. This worksheet is part of your system documentation. You may need this worksheet when modifying or trouble shooting your system.